

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



1 of 2

**RESULT: Satisfactory**

**Facility Information**

Permit Number: 13-51-08262 Name of Facility: G. Holmes Braddock Senior High Address: 3601 SW 147 Avenue City, Zip: Miami 33185  Type: Public School Owner: M-DCSB Food and Nutrition Person In Charge: Manuel S. Garcia      Phone: 305-225-9729 ext2102	<b>Correct By: Next Inspection</b> <b>Re-Inspection Date: None</b>
---	---

**Inspection Information**

Purpose: Reinspection Inspection Date: 8/17/2016	Begin Time: 11:00 AM End Time: 12:30 PM
---	--

**Additional Information**

CENSUS	3396
FEMALES	1632
MALES	1764

*As per section 120.695 of the Florida Statutes (FS), this form will serve as a "Notice of Non-Compliance: for any violations noted. Items marked below violate the requirements of Chapters 64E-13 and 64E-11 of the Florida Administrative Code (FAC) and must be corrected within the time period indicated in the "Results" section above. Continued operation of this facility without making these corrections is a violation of Chapter 64E-13 and 64E-11, FAC, and Chapter 381, FS. Failure to correct violations may result in an administrative fine or other legal action being initiated or continued.*

**Violation Markings**

SCHOOL SANITATION 1. School Site 2. Playground Equipment 3. Athletic Equipment BUILDINGS 4. Construction 5. Maintenance & Repair 6. Lighting/Foot-Candles 7. Heating, Ventilation, A/C 8. Natural Ventilation X 9. Mechanical Ventilation SANITARY FACILITIES 10. Provided/Accessible	11. Cleanliness & Repair 12. Toilet Facilities 13. Separation of Sexes 14. Fixture Ratio 15. Handwash Facilities 16. Showers/Fixtures 17. Shower Water Temp. WATER SUPPLY 18. Installed/Operated/Maintained X 19. Drinking Fountains 20. Approved Source LIQUID/SOLID WASTE 21. Sewage Disposal	22. Solid Waste VECTOR/VERMIN CONTROL 23. Infestation/Control 24. Brush/Trash 25. Water Collection/Drainage SAFETY 26. First Aid Kit FOOD 27. Food Insp. Rpt. OTHER 28. 29.
---	---	--

**General Comments**

No General Comments Available  Email Address(es): msgarcia@dadeschools.net
--

Inspector Signature:

*Terrence...*

Client Signature:

*Manuel S. Garcia*

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



2 of 2

**Violations Comments**

**Violation #9. Mechanical Ventilation**

Repair mechanical ventilations not working in bath 3105 and 4239

CODE REFERENCE: Mechanical Ventilation 64E-13.004(5)(d). All spaces which do not meet the requirements for natural ventilation shall be mechanically ventilated by means of electrically operated exhausts. Fans and blowers shall be sized and designed to provide the required air movement without excessive or disturbing noise. Special provisions shall be made in the design of ventilation systems in areas of high air contamination such as paint shops, auto repair shops and chemistry laboratories, art rooms where kilns are used, wood working, and metal shops, chemical storerooms. A high capacity emergency exhaust system is recommended for chemistry laboratories. All air conditioned spaces shall be ventilated when occupied.

**Violation #19. Drinking Fountains**

Repair the following water fountains that are not working 1215,1175,4239

CODE REFERENCE: Drinking Fountains 64E-13.004(7)(b). Drinking fountains of an approved, sanitary slant jet type shall be provided in the ratio specified in the local building code or Chapter 64E-10, F.A.C. In no case shall fountains be located in any toilet room.

Inspection Conducted By: Zenaida Triana (27455)

Work: (305) 623-3500 ex.

Date: 8/17/2016

Inspector Signature:

Handwritten signature of Zenaida Triana in black ink.

Client Signature:

Handwritten signature of the client in black ink.